



Return address: P.O. Box 2280 AA Rijswijk The Netherlands


VPAM

 Vereinigung der
 Prüfstellen für angriffs-
 hemmende Materialien
 und Konstruktionen

Lange Kleiweg 137
 Postbus 45
 2280 AA Rijswijk

www.tno.nl

T +31 8886 68000
 info-DenV@tno.nl

Laboratory for Ballistics
 Research (LBR)
 Visiting address:
 Suburb Ypenburg
 Ypenburgse Boslaan 2
 2496 ZA The Hague
 The Netherlands

Test report *

The test has been carried out according to **EN 1522:1998**
 class **FB4, .357 CB**

Assignor **AKAB**
 Industriegebied "Parkstad 8030" Handelstraat 18A
 6433 KB Hoensbroek
 Nederland

Subject

Ballistic experiments

Date

28-11-2014

Reference

14MB03194 / 14MB03195

Contact

M.H. Dijkstra

E-mail

mark.dijkstra@tno.nl

Direct dialing

+31 15 2843733

Experiment date 14-10-2014

Project Door + frame

Sample identification Sample - 3;
 Sample - 4 (.357)

For details see page 2 upto page 6.

The sample - 3 (14MB03194) and sample - 4 (14MB03195) fulfills the ballistic requirements according to 'EN 1522:1998' level 'FB4 S, .357 CB'.

The EN 1522:1998' level 'FB4 prescribes two projectiles, the other one is the .44 FMJ-FN.

K. Breeman

Project leader

* This report is based on data obtained from having tested only the samples submitted and should not be interpreted as an endorsement by TNO of the continuing quality or performance of any other items of the same or similar design

The General Terms and Conditions for commissions to TNO, as filed with the Registry of the District Court in the Hague and with the Chamber of Commerce and Industry in The Hague, shall apply to all commissions to TNO.